

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9		.52		
2	7.9		.64		
3	8.0		.57		
4	8.0		.64		
5	8.1		.55		
6	8.1		.52		
7	8.1		.55		
8	8.2		.62		
9	8.2		.65		
10	8.1		.60		
11	8.2		.60		
12	8.2		.56		
13	8.1		.55		
14	8.3		.52		
15	8.3		.51		
16	8.3		.65		
17	8.3		.65		
18	8.5		.61		
19	8.3		.61		
20	8.3		.65		
21	8.3		.60		
22	8.4		.60		
23	8.3		.65		
24	8.3		.60		
25	8.3		.65		
26	8.3		.65		
27	8.3		.65		
28	8.3		.60		
29	8.3		.60		
30	8.3		.55		
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: 9-1-2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other (_____)

Print Name: Anthony Morales

Signature: _____

Date: 10/4/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's