

Day	pH	Alk	Phos	Other	Y/N
1	8.3		.60		
2	8.0		.55		
3	8.2		.60		
4	8.3		.50		
5	8.3		.55		
6	8.3		.65		
7	8.3		.50		
8	8.2		.60		
9	8.3		.65		
10	8.3		.55		
11	8.3		.60		
12	8.3		.55		
13	8.3		.60		
14	8.3		.60		
15	8.3		.60		
16	8.3		.60		
17	8.3		.55		
18	8.3		.55		
19	8.3		.60		
20	8.7		.60		
21	8.9		.60		
22	9.0		.55		
23	8.3		.65		
24	8.3		.60		
25	8.3		.60		
26	8.2		.65		
27	8.3		.55		
28	8.3		.55		
29	8.3		.60		
30	8.3		.60		
31	8.3		.55		

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: 10.1-2021
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3

Alk — (Alkalinity)

PO4 0.5 (Orthophosphate)

Other — (_____)

Print Name: Anthony Morales

Signature: _____

Date: 11/6/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's N