

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.3		.50		
2	8.2		.55		
3	8.2		.65		
4	8.3		.55		
5	8.3		.60		
6	8.3		.60		
7	8.3		.55		
8	8.3		.55		
9	8.2		.60		
10	8.7		.65		
11	8.3		.55		
12	8.3		.55		
13	8.4		.50		
14	8.4		.50		
15	8.3		.55		
16	8.3		.65		
17	8.3		.55		
18	8.3		.55		
19	8.3		.60		
20	8.3		.60		
21	8.3		.60		
22	8.3		.55		
23	8.3		.55		
24	8.3		.60		
25	8.4		.55		
26	8.3		.60		
27	8.3		.60		
28	8.2		.55		
29	8.2		.55		
30	8.2		.50		
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: 11-2021
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other (_____)

Print Name: Anthony Morales

Signature: _____

Date: 12/5/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's