

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	8.3		.55		
2	8.1		.65		
3	8.1		.55		
4	8.1		.60		
5	8.0		.50		
6	8.0		.55		
7	8.1		.60		
8	8.0		.55		
9	8.0		.55		
10	8.0		.50		
11	7.8		.50		
12	7.8		.55		
13	7.8		.55		
14	7.8		.60		
15	7.8		.60		
16	7.8		.55		
17	7.8		.55		
18	7.8		.50		
19	7.9		.55		
20	7.9		.50		
21	7.9		.50		
22	7.9		.55		
23	7.9		.55		
24	7.9		.50		
25	7.9		.50		
26	7.9		.50		
27	7.9		.55		
28	7.8		.50		
29	7.8		.50		
30	7.9		.55		
31	7.8		.50		

(No = N = Excursion) Total N's N

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: \_\_\_\_\_

Sample Period: 12-2021  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.3

Alk — (Alkalinity)

PO4 0.5 (Orthophosphate)

Other — (\_\_\_\_\_)

Print Name: Anthony Morales

Signature: \_\_\_\_\_

Date: 1-7-22

Send to DWP within 10 days after end of sampling period