

Day	pH	Alk	Phos	Other	Y/N
1	7.8		.55		
2	7.9		.50		
3	7.8		.50		
4	7.8		.55		
5	7.8		.60		
6	7.7		.55		
7	7.7		.55		
8	7.8		.55		
9	7.7		.55		
10	7.7		.50		
11	7.7		.50		
12	7.6		.50		
13	7.7		.50		
14	7.7		.55		
15	7.7		.50		
16	7.7		.50		
17	7.7		.60		
18	7.6		.55		
19	7.7		.55		
20	7.7		.50		
21	7.6		.50		
22	7.6		.60		
23	7.7		.55		
24	7.6		.50		
25	7.6		.55		
26	7.7		.60		
27	8.7		.65		
28	7.6		.55		
29	7.7		.60		
30	7.7		.60		
31	7.7		.55		

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: \_\_\_\_\_

Sample Period: 1 - 2022  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	7.3	
Alk	—	(Alkalinity)
PO4	0.5	(Orthophosphate)
Other	—	(_____)

Print Name: Anthony Morales

Signature: 

Date: 2-7-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0