

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | 7.6 | | .50 | | |
| 2 | 7.7 | | .50 | | |
| 3 | 7.8 | | .55 | | |
| 4 | 7.7 | | .55 | | |
| 5 | 7.8 | | .60 | | |
| 6 | 7.8 | | .60 | | |
| 7 | 7.7 | | .50 | | |
| 8 | 7.8 | | .55 | | |
| 9 | 7.8 | | .65 | | |
| 10 | 7.7 | | .55 | | |
| 11 | 7.8 | | .55 | | |
| 12 | 7.9 | | .55 | | |
| 13 | 7.7 | | .60 | | |
| 14 | 7.6 | | .50 | | |
| 15 | 7.7 | | .50 | | |
| 16 | 7.7 | | .50 | | |
| 17 | 7.7 | | .60 | | |
| 18 | 7.8 | | .50 | | |
| 19 | 7.9 | | .65 | | |
| 20 | 7.8 | | .50 | | |
| 21 | 7.8 | | .50 | | |
| 22 | 7.9 | | .50 | | |
| 23 | 7.8 | | .55 | | |
| 24 | 7.8 | | .55 | | |
| 25 | 7.9 | | .55 | | |
| 26 | 7.7 | | .50 | | |
| 27 | 7.7 | | .55 | | |
| 28 | 7.9 | | .50 | | |
| 29 | 7.7 | | .50 | | |
| 30 | 7.7 | | .55 | | |
| 31 | 7.7 | | .55 | | |

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: 3/2022
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3

Alk - (Alkalinity)

PO4 0.5 (Orthophosphate)

Other - (_____)

Print Name: Anthony Morales

Signature: _____

Date: 4-5-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's N