

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5		.50		
2	7.6		.65		
3	7.6		.65		
4	7.7		.60		
5	7.7		.60		
6	7.8		.55		
7	7.6		.60		
8	7.6		.60		
9	7.5		.50		
10	7.5		.65		
11	7.5		.65		
12	7.5		.60		
13	7.4		.60		
14	7.6		.60		
15	7.5		.60		
16	7.6		.60		
17	7.5		.55		
18	7.7		.55		
19	7.6		.55		
20	7.5		.65		
21	7.5		.60		
22	7.6		.65		
23	7.6		.60		
24	7.6		.55		
25	7.5		.65		
26	7.5		.65		
27	7.5		.65		
28	7.4		.70		
29	7.5		.60		
30	7.5		.60		
31	7.5		.60		

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: 5-2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3
 Alk — (Alkalinity)
 PO4 0.5 (Orthophosphate)
 Other — (_____)

Print Name: Anthony Morales

Signature: _____

Date: 6.2.22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's No