

Day	pH	Alk	Phos	Other	Y/N
1	7.9		.50		
2	7.8		.55		
3	7.4		.65		
4	7.5		.55		
5	7.4		.55		
6	7.3		.60		
7	7.3		.55		
8	7.3		.50		
9	7.4		.55		
10	7.5		.60		
11	7.5		.60		
12	7.5		.55		
13	7.5		.55		
14	7.8		.55		
15	7.9		.60		
16	8.0		.55		
17	8.0		.55		
18	7.6		.50		
19	7.3		.60		
20	7.4		.65		
21	7.5		.65		
22	7.6		.55		
23	7.7		.65		
24	7.6		.60		
25	7.9		.65		
26	7.4		.60		
27	7.5		.60		
28	7.6		.60		
29	7.7		.65		
30	7.9		.60		
31	7.5		.60		

(No = N = Excursion) **Total N's** N

<<Have minimums been met for this day? **ENTRY POINT**

**PWS ID: 41** 00835

**System Name:** Shangri-La Water Dist.

**Entry Point:** \_\_\_\_\_

**Sample Period:** 9/2022  
Month/Year

**Number of excursions\* during this month:** \_\_\_\_\_  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.3

Alk   (Alkalinity)

PO4 0.5 (Orthophosphate)

Other   (\_\_\_\_\_)

*Eric Carlson 9-7-22*

**Print Name:** Anthony Morales

**Signature:** \_\_\_\_\_

**Date:** 9-5-22

Send to DWP within 10 days after end of sampling period