

Day	pH	Alk	Phos	Other	Y/N
1	7.5		.70		
2	7.4		.65		
3	7.4		.65		
4	7.3		.65		
5	7.4		.65		
6	7.3		.65		
7	7.3		.65		
8	7.3		.65		
9	7.4		.60		
10	7.5		.55		
11	7.5		.55		
12	7.5		.55		
13	7.5		.60		
14	7.4		.65		
15	7.3		.60		
16	7.3		.65		
17	7.4		.60		
18	7.4		.55		
19	7.4		.65		
20	7.4		.60		
21	7.4		.60		
22	7.4		.60		
23	7.5		.60		
24	7.5		.60		
25	7.5		.60		
26	7.6		.55		
27	7.6		.60		
28	7.7		.55		
29	7.7		.55		
30	7.6		.60		
31	7.5		.60		

(No = N = Excursion) Total N's 2

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name: Shangri-La

Entry Point: _____

Sample Period: Oct / 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.3	
Alk		(Alkalinity)
PO4	0.5	(Orthophosphate)
Other		(_____)

*Eric Carlson 11-3-22
T-0901*

Print Name: Anthony Morales

Signature: _____

Date: 11-3-2022

Send to DWP within 10 days after end of sampling period