

Day	pH	Alk	Phos	Other	Y/N
1	7.5		.55		
2	7.6		.60		
3	7.6		.55		
4	7.5		.60		
5	7.7		.60		
6	7.6		.60		
7	7.5		.55		
8	7.6		.55		
9	7.6		.60		
10	7.5		.60		
11	7.5		.55		
12	7.5		.55		
13	7.5		.55		
14	7.5		.60		
15	7.4		.60		
16	7.4		.60		
17	7.5		.60		
18	7.4		.55		
19	7.4		.60		
20	7.4		.60		
21	7.5		.60		
22	7.5		.55		
23	7.4		.60		
24	7.4		.60		
25	7.4		.55		
26	7.5		.55		
27	7.5		.60		
28	7.6		.55		
29	7.6		.55		
30	7.5		.60		
31					

(No = N = Excursion) Total N's **No**

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 **008357**

System Name: Shangri-La Water Dist.

Entry Point: \_\_\_\_\_

Sample Period: 11/2022  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH **7.3**

Alk \_\_\_\_\_ (Alkalinity)

PO4 **0.5** (Orthophosphate)

Other \_\_\_\_\_ (\_\_\_\_\_)

*Eric Carlson 12-5-22 7-09011*

Print Name: Anthony Morales

Signature: \_\_\_\_\_

Date: 12-4-22

Send to DWP within 10 days after end of sampling period