

Day	pH	Alk	Phos	Other	Y/N
1	7.7		.60		N
2	7.6		.55		
3	7.7		.65		
4	7.8		.60		
5	7.7		.60		
6	7.6		.60		
7	7.7		.65		
8	7.7		.60		
9	7.7		.60		
10	7.6		.55		
11	7.7		.55		
12	7.6		.60		
13	7.7		.65		
14	7.4		.65		
15	7.4		.60		
16	7.5		.60		
17	7.7		.65		
18	7.6		.60		
19	7.6		.60		
20	7.6		.60		
21	7.6		.60		
22	7.6		.60		
23	7.6		.55		
24	7.7		.55		
25	7.6		.60		
26	7.6		.60		
27	8.0		.65		
28	7.8		.65		
29	7.8		.60		
30	7.6		.60		
31	7.6		.65		

(No = N = Excursion) **Total N's** N

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name: Shangri-La Water Dist.

Entry Point: _____

Sample Period: Jan/2023
Month/Year 1-2023

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3
Alk _____ (Alkalinity)
PO4 0.5 (Orthophosphate)
Other _____ (_____)

Eric Carlson 2-6-23

Anthony Morales

Print Name: Anthony Morales

Signature: [Signature]

Date: 2/3/24

Send to DWP within 10 days after end of sampling period