

Day	pH	Alk	Phos	Other	Y/N
1	7.7		.60		
2	7.5		.60		
3	7.6		.60		
4	7.6		.65		
5	7.6		.60		
6	7.4		.60		
7	7.6		.60		
8	7.6		.60		
9	7.5		.50		
10	7.7		.55		
11	7.6		.60		
12	7.6		.60		
13	7.6		.60		
14	7.6		.60		
15	7.5		.65		
16	7.5		.60		
17	7.5		.60		
18	7.6		.60		
19	7.5		.60		
20	7.6		.60		
21	7.7		.60		
22	7.5		.65		
23	7.5		.65		
24	7.5		.60		
25	7.5		.60		
26	7.5		.60		
27	7.4		.60		
28	7.5		.60		
29	7.6		.60		
30	7.6		.60		
31	7.6		.55		

(No = N = Excursion) Total N's ND

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name: Shangri-La Water Dist.

Entry Point: _____

Sample Period: March / 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3
Alk _____ (Alkalinity)
PO4 0.5 (Orthophosphate)
Other _____ (_____)

Eric Carlson 4-5-23

Print Name: Anthony Morales

Signature: _____

Date: 4-3-23

Send to DWP within 10 days after end of sampling period