

| Day | pH  | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1   | 7.6 |     | .55  |       | N   |
| 2   | 7.7 |     | .60  |       |     |
| 3   | 7.6 |     | .60  |       |     |
| 4   | 7.7 |     | .60  |       |     |
| 5   | 7.5 |     | .60  |       |     |
| 6   | 7.4 |     | .50  |       |     |
| 7   | 7.4 |     | .55  |       |     |
| 8   | 7.4 |     | .55  |       |     |
| 9   | 7.5 |     | .60  |       |     |
| 10  | 7.3 |     | .60  |       |     |
| 11  | 7.3 |     | .60  |       |     |
| 12  | 7.4 |     | .60  |       |     |
| 13  | 7.4 |     | .65  |       |     |
| 14  | 7.3 |     | .60  |       |     |
| 15  | 7.3 |     | .60  |       |     |
| 16  | 7.3 |     | .60  |       |     |
| 17  | 7.4 |     | .55  |       |     |
| 18  | 7.4 |     | .55  |       |     |
| 19  | 7.4 |     | .60  |       |     |
| 20  | 7.4 |     | .60  |       |     |
| 21  | 7.5 |     | .60  |       |     |
| 22  | 7.6 |     | .60  |       |     |
| 23  | 7.6 |     | .60  |       |     |
| 24  | 7.5 |     | .60  |       |     |
| 25  | 7.6 |     | .65  |       |     |
| 26  | 7.5 |     | .65  |       |     |
| 27  | 7.5 |     | .65  |       |     |
| 28  | 7.6 |     | .60  |       |     |
| 29  | 7.5 |     | .65  |       |     |
| 30  | 7.4 |     | .65  |       |     |
| 31  | 7.4 |     | .60  |       |     |

(No = N = Excursion) Total N's **N**

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: Shenandoah Water Dist.

Entry Point: \_\_\_\_\_

Sample Period: 5/2023  
Month/Year 5-2023

Number of excursions\* during this month: \_\_\_\_\_  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

*Eric Carlson 6-5-23*

Print Name: Anthony Morales

Signature: \_\_\_\_\_

Date: 6.5.23

Send to DWP within 10 days after end of sampling period