

Day	pH	Alk	Phos	Other	Y/N
1	7.3		.60		N
2	7.3		.60		
3	7.4		.60		
4	7.3		.65		
5	7.3		.65		
6	7.3		.65		
7	7.3		.65		
8	7.4		.65		
9	7.4		.60		
10	7.5		.60		
11	7.7		.60		
12	7.6		.60		
13	7.4		.60		
14	7.3		.65		
15	7.3		.65		
16	7.3		.60		
17	7.4		.60		
18	7.3		.60		
19	8.0		.60		
20	7.5		.60		
21	7.4		.60		
22	7.4		.65		
23	7.6		.65		
24	7.6		.60		
25	7.3		.60		
26	7.3		.60		
27	7.3		.60		
28	7.4		.65		
29	7.3		.65		
30	7.3		.60		
31					

(No = N = Excursion) Total N's **N**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 **00835**

System Name: Shangri-La Water

Entry Point: _____

Sample Period: 05/2023
Month/Year 6-2023

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH **7.3**

Alk _____ (Alkalinity)

PO4 **0.5** (Orthophosphate)

Other _____ (_____)

Eric Carlson 7-6-23

Print Name: Anthony Morales

Signature: _____

Date: 7/5/23

Send to DWP within 10 days after end of sampling period