

Day	pH	Alk	Phos	Other	Y/N
1	7.4		.60		
2	7.6		.60		
3	7.6		.60		
4	7.6		.65		
5	7.7		.65		
6	7.6		.60		
7	7.7		.60		
8	7.7		.65		
9	7.6		.60		
10	7.9		.60		
11	7.9		.60		
12	7.8		.60		
13	7.7		.60		
14	7.7		.60		
15	7.8		.65		
16	7.4		.60		
17	7.3		.60		
18	7.3		.60		
19	7.6		.60		
20	7.4		.60		
21	7.4		.60		
22	7.3		.60		
23	7.3		.65		
24	7.3		.65		
25	7.4		.65		
26	7.5		.60		
27	7.5		.60		
28	7.6		.60		
29	7.5		.65		
30	7.5		.60		
31	7.5		.60		

(No = N = Excursion) Total N's N

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name:

Entry Point:

Sample Period: 7-2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3

Alk (Alkalinity)

PO4 0.5 (Orthophosphate)

Other ()

Eric Carlson 8-4-25

Print Name: Anthony Morales

Signature:

Date: 8/3/23

Send to DWP within 10 days after end of sampling period