

Day	pH	Alk	Phos	Other	Y/N
1	7.6		.60		
2	7.6		.60		
3	7.3		.65		
4	7.5		.65		
5	7.3		.65		
6	7.5		.60		
7	7.3		.60		
8	7.3		.60		
9	7.3		.65		
10	7.3		.65		
11	7.4		.65		
12	7.3		.65		
13	7.3		.65		
14	7.3		.60		
15	7.3		.60		
16	7.3		.65		
17	7.4		.60		
18	7.4		.60		
19	7.3		.55		
20	7.3		.60		
21	7.4		.60		
22	7.3		.65		
23	7.3		.60		
24	7.3		.60		
25	7.3		.65		
26	7.4		.65		
27	7.3		.65		
28	7.4		.60		
29	7.6		.65		
30	7.7		.70		
31					

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00835

System Name: Shangri-La Water

Entry Point: _____

Sample Period: 8-2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by


pH 7.3

Alk _____ (Alkalinity)

PO4 0.5 (Orthophosphate)

Other _____ (_____)

Print Name: Anthony Morales

Signature: 

Date: 9.5.23

Send to DWP within 10 days after end of sampling period