

Day	pH	Alk	Phos	Other	Y/N
1	7.60		.60		
2	7.8		.50		
3	7.8		.50		
4	7.7		.55		
5	7.9		.55		
6	7.9		.55		
7	7.8		.55		
8	7.8		.55		
9	7.8		.55		
10	7.4		.55		
11	7.9		.60		
12	7.9		.55		
13	7.9		.50		
14	7.8		.50		
15	7.8		.55		
16	7.7		.50		
17	7.8		.55		
18	7.8		.55		
19	7.7		.55		
20	7.7		.55		
21	7.6		.50		
22	7.6		.50		
23	7.5		.55		
24	7.6		.50		
25	7.5		.50		
26	7.5		.50		
27	7.6		.50		
28	7.5		.55		
29	7.7		.55		
30	7.6		.55		
31	7.6		.55		

(No = N = Excursion) Total N's **N**

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Shanigric Water

Entry Point: _____

Sample Period: 10-2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3

Alk _____ (Alkalinity)

PO4 0.5 (Orthophosphate)

Other _____ (_____)

Eric Carlson 11/6/23

Print Name: Anthony Morales

Signature: _____

Date: 11-3-23

Send to DWP within 10 days after end of sampling period