

Day	pH	Alk	Phos	Other	Y/N
1	7.6		.55		N
2	7.5		.55		
3	7.6		.60		
4	7.6		.60		
5	7.6		.65		
6	7.6		.65		
7	7.5		.65		
8	7.6		.65		
9	7.5		.65		
10	7.6		.65		
11	7.5		.60		
12	7.6		.65		
13	7.5		.65		
14	7.5		.65		
15	7.6		.60		
16	7.6		.60		
17	7.6		.60		
18	7.6		.55		
19	7.5		.55		
20	7.6		.55		
21	7.5		.55		
22	7.5		.50		
23	7.6		.55		
24	7.6		.55		
25	7.5		.55		
26	7.4		.60		
27	7.4		.60		
28	7.4		.60		
29	7.4		.60		
30	7.3		.60		
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: \_\_\_\_\_

Sample Period: 11-2023  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.3

Alk - (Alkalinity)

PO4 0.5 (Orthophosphate)

Other - (\_\_\_\_\_)

Eric Carlson 12-7-23

Print Name: Anthony Morales

Signature: \_\_\_\_\_

Date: 12-6-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's N