

Day	pH	Alk	Phos	Other	Y/N
1	7.3		.60		N
2	7.3		.60		
3	7.4		.60		
4	7.3		.65		
5	7.4		.55		
6	7.3		.55		
7	7.3		.60		
8	7.3		.60		
9	7.3		.60		
10	7.5		.55		
11	7.4		.55		
12	7.5		.55		
13	7.5		.55		
14	7.6		.55		
15	7.5		.55		
16	7.5		.60		
17	7.6		.60		
18	7.3		.55		
19	7.4		.55		
20	7.4		.55		
21	7.3		.55		
22	7.4		.60		
23	7.3		.55		
24	7.3		.55		
25	7.3		.55		
26	7.3		.60		
27	7.3		.60		
28	7.3		.55		
29	7.4		.55		
30	7.5		.60		
31	7.5		.60		

(No = N = Excursion) Total N's N

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00835

System Name: Shangri La Water Dist

Entry Point: _____

Sample Period: 12-2023
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3

Alk - (Alkalinity)

PO4 0.5 (Orthophosphate)

Other - (_____)

Eric Carlson 1-5-24

Print Name: Anthony Morales

Signature: _____

Date: 1-4-24

Send to DWP within 10 days after end of sampling period