

Day	pH	Alk	Phos	Other	Y/N
1	7.5		.55		
2	7.4		.55		
3	7.3		.60		
4	7.5		.65		
5	7.5		.65		
6	7.4		.60		
7	7.4		.60		
8	7.5		.60		
9	7.5		.65		
10	7.5		.60		
11	7.4		.60		
12	7.4		.60		
13	7.5		.60		
14	7.6		.60		
15	7.6		.60		
16	7.6		.55		
17	7.6		.55		
18	7.6		.50		
19	7.6		.50		
20	7.6		.55		
21	7.6		.55		
22	7.6		.55		
23	7.7		.55		
24	7.8		.50		
25	7.9		.55		
26	7.9		.55		
27	7.9		.55		
28	8.0		.55		
29	7.8		.55		
30	7.8		.60		
31	7.9		.60		

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: \_\_\_\_\_

Sample Period: 1-2024  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.3

Alk - (Alkalinity)

PO4 0.5 (Orthophosphate)

Other - (\_\_\_\_\_)

Eric Carlson 2-4-24

Print Name: Anthony Morales

Signature: \_\_\_\_\_

Date: 2-4-24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's N