

Day	pH	Alk	Phos	Other	Y/N
1	7.7		.55		
2	7.7		.55		
3	7.8		.50		
4	7.7		.50		
5	7.8		.55		
6	8.2		.55		
7	8.1		.55		
8	8.1		.55		
9	8.1		.55		
10	8.1		.55		
11	8.0		.60		
12	8.0		.60		
13	7.9		.60		
14	7.3		.55		
15	7.3		.55		
16	7.3		.55		
17	7.5		.55		
18	7.4		.55		
19	7.3		.60		
20	7.5		.60		
21	7.6		.55		
22	7.7		.55		
23	7.7		.55		
24	7.6		.60		
25	7.6		.60		
26	7.6		.55		
27	7.6		.55		
28	7.7		.55		
29	7.6		.60		
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: 2-2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3
Alk — (Alkalinity)
PO4 0.5 (Orthophosphate)
Other — (_____)

Eric Carlson 3-5-24

Print Name: Anthony Morales

Signature: _____

Date: 3/4/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's N