

Day	pH	Alk	Phos	Other	Y/N
1	7.5		.60		
2	7.6		.60		
3	7.6		.55		
4	7.7		.55		
5	7.8		.60		
6	7.8		.60		
7	7.8		.65		
8	8.0		.60		
9	8.0		.60		
10	8.1		.55		
11	8.1		.65		
12	8.4		.65		
13	8.4		.60		
14	8.3		.60		
15	8.1		.60		
16	8.4		.55		
17	8.2		.55		
18	8.3		.60		
19	8.2		.60		
20	8.1		.60		
21	8.2		.55		
22	8.3		.55		
23	7.4		.60		
24	7.5		.60		
25	7.5		.55		
26	7.4		.55		
27	7.5		.60		
28	7.5		.60		
29	7.5		.60		
30	7.5		.55		
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: 3-2024
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3

Alk - (Alkalinity)

PO4 0.5 (Orthophosphate)

Other - (_____)

Eric Carlson 4-4-24

Print Name: Anthony Morales

Signature: _____

Date: 4-4-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's N