

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.8		.50		N
2	7.9		.50		N
3	7.8		.55		N
4	7.9		.55		N
5	8.0		.60		N
6	8.0		.60		N
7	8.0		.55		N
8	7.7		.55		N
9	7.7		.60		N
10	7.8		.60		N
11	7.9		.55		N
12	7.7		.55		N
13	7.8		.60		N
14	7.9		.60		N
15	7.8		.55		N
16	7.4		.55		N
17	7.5		.55		N
18	7.4		.60		N
19	7.5		.60		N
20	7.6		.60		N
21	7.7		.55		N
22	7.4		.55		N
23	7.3		.50		N
24	7.3		.55		N
25	7.4		.55		N
26	7.5		.56		N
27	7.5		.55		N
28	7.7		.60		N
29	7.8		.60		N
30	7.8		.55		N
31	7.6		.55		N

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: July-2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.3"/>	
Alk	<input type="text" value=""/>	(Alkalinity)
PO4	<input type="text" value="0.5"/>	(Orthophosphate)
Other	<input type="text" value=""/>	(_____)

Eric Carlson 8-6-24

Print Name: Anthony Morales

Signature: _____

Date: _____

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's