

Day	pH	Alk	Phos	Other	Y/N
1	7.4		.60		N
2	7.5		.60		N
3	7.6		.55		N
4	7.8		.55		N
5	7.9		.55		N
6	7.9		.60		N
7	8.0		.60		N
8	8.0		.55		N
9	7.9		.55		N
10	7.9		.60		N
11	7.8		.60		N
12	7.6		.55		N
13	7.7		.50		N
14	7.6		.55		N
15	7.8		.55		N
16	7.9		.60		N
17	7.9		.60		N
18	7.9		.50		N
19	7.9		.55		N
20	8.0		.55		N
21	7.7		.60		N
22	7.8		.55		N
23	7.8		.60		N
24	7.7		.60		N
25	7.8		.55		N
26	7.9		.55		N
27	7.9		.60		N
28	7.7		.60		N
29	7.7		.55		N
30	7.8		.55		N
31	7.8		.55		N

(No = N = Excursion) Total N's 31

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: Aug / 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3

Alk - (Alkalinity)

PO4 0.5 (Orthophosphate)

Other - (_____)

Eric Carlson 9-6-24

Print Name: Anthony Morales

Signature: _____

Date: 9/4/24

Send to DWP within 10 days after end of sampling period