

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.7		.65		N
2	7.8		.65		N
3	7.9		.60		N
4	7.9		.60		N
5	8.0		.55		N
6	8.0		.65		N
7	7.9		.65		N
8	7.8		.60		N
9	7.7		.60		N
10	7.8		.60		N
11	7.8		.55		N
12	7.9		.60		N
13	7.9		.60		N
14	7.8		.50		N
15	7.8		.50		N
16	7.8		.55		N
17	7.9		.55		N
18	7.9		.55		N
19	8.0		.60		N
20	7.8		.55		N
21	7.7		.55		N
22	7.9		.60		N
23	7.9		.50		N
24	7.9		.55		N
25	8.0		.55		N
26	7.9		.60		N
27	7.9		.60		N
28	7.8		.55		N
29	7.8		.55		N
30	7.7		.55		N
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: Shangri-La Water Dist

Entry Point: \_\_\_\_\_

Sample Period: NOV-2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

Eric Carlson 12-5-24

Print Name: Anthony Morales

Signature: \_\_\_\_\_

Date: 12-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's