

Day	pH	Alk	Phos	Other	Y/N
1	7.8		.55		N
2	7.8		.55		N
3	7.9		.55		N
4	7.9		.50		N
5	8.0		.50		N
6	8.0		.55		N
7	7.7		.60		N
8	7.7		.60		N
9	7.7		.55		N
10	7.6		.55		N
11	7.6		.60		N
12	7.6		.60		N
13	7.6		.55		N
14	7.5		.55		N
15	7.5		.60		N
16	7.5		.60		N
17	7.5		.55		N
18	7.6		.55		N
19	7.5		.65		N
20	7.6		.65		N
21	7.5		.60		N
22	7.6		.60		N
23	7.6		.55		N
24	7.6		.55		N
25	7.7		.55		N
26	7.7		.60		N
27	7.6		.60		N
28	7.7		.60		N
29	7.8		.55		N
30	7.5		.65		N
31	7.6		.65		N

(No = N = Excursion) Total N's 31

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: \_\_\_\_\_

Sample Period: Dec/2024  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.3

Alk \_\_\_\_\_ (Alkalinity)

PO4 0.5 (Orthophosphate)

Other \_\_\_\_\_ (\_\_\_\_\_)

Eric Carlson 1-6-25

Print Name: Anthony Morales

Signature: \_\_\_\_\_

Date: 1-2-25

Send to DWP within 10 days after end of sampling period