

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6		.55		N
2	7.5		.55		N
3	7.5		.50		N
4	7.6		.55		N
5	7.6		.55		N
6	7.7		.55		N
7	7.8		.60		N
8	7.7		.60		N
9	7.6		.60		N
10	7.5		.55		N
11	7.4		.55		N
12	7.4		.55		N
13	7.5		.50		N
14	7.5		.50		N
15	7.6		.55		N
16	7.6		.55		N
17	7.7		.60		N
18	7.7		.60		N
19	7.5		.60		N
20	7.8		.55		N
21	7.5		.55		N
22	7.5		.60		N
23	7.7		.60		N
24	7.8		.55		N
25	7.7		.55		N
26	7.7		.60		N
27	7.8		.60		N
28	7.7		.60		N
29	7.7		.55		N
30	7.8		.55		N
31	7.8		.60		N

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: Jan / 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3
 Alk _____ (Alkalinity)
 PO4 0.5 (Orthophosphate)
 Other _____ (_____)

Eric Carlson 2-6-25

Print Name: Anthony Morales

Signature: _____

Date: 2-5-2025

Send to DWP within 10 days after end of sampling period