

Day	pH	Alk	Phos	Other	Y/N
1	7.6		.60		N
2	7.6		.62		N
3	7.6		.60		N
4	7.5		.53		N
5	7.5		.56		N
6	7.4		.58		N
7	7.4		.65		N
8	7.5		.67		N
9	7.6		.69		N
10	7.6		.67		N
11	7.7		.70		N
12	7.7		.67		N
13	7.7		.55		N
14	7.6		.57		N
15	7.6		.60		N
16	7.5		.55		N
17	7.6		.55		N
18	7.6		.60		N
19	7.8		.65		N
20	7.5		.53		N
21	7.5		.55		N
22	7.6		.55		N
23	7.6		.50		N
24	7.6		.51		N
25	7.6		.55		N
26	7.5		.57		N
27	7.6		.55		N
28	7.6		.53		N
29	7.4		.53		N
30	7.5		.60		N
31	7.6		.59		N

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: March / 2026
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3

Alk (Alkalinity)

PO4 0.5 (Orthophosphate)

Other (_____)

Eric Carlson 4/6/26 T-09011

Print Name: Anthony Morales

Signature: *[Signature]*

Date: 4/3/26

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0