

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.8	-	-	-	Y
2	7.8	-	-	-	Y
3	7.9	-	-	-	Y
4	7.9	-	-	-	Y
5	7.9	-	-	-	Y
6	7.9	-	-	-	Y
7	7.9	-	-	-	Y
8	7.9	-	-	-	Y
9	7.9	-	-	-	Y
10	7.8	-	-	-	Y
11	7.8	-	-	-	Y
12	7.7	-	-	-	Y
13	7.7	-	-	-	Y
14	7.7	-	-	-	Y
15	7.7	-	-	-	Y
16	7.7	-	-	-	Y
17	7.7	-	-	-	Y
18	7.7	-	-	-	Y
19	7.7	-	-	-	Y
20	7.7	-	-	-	Y
21	7.7	-	-	-	Y
22	7.7	-	-	-	Y
23	7.6	-	-	-	Y
24	7.7	-	-	-	Y
25	7.7	-	-	-	Y
26	7.7	-	-	-	Y
27	7.7	-	-	-	Y
28	7.7	-	-	-	Y
29	7.7	-	-	-	Y
30	7.7	-	-	-	Y
31	7.7	-	-	-	Y

(N = Excursion)

**Total N's    0**

ENTRY POINT \_\_\_\_\_

**PWS ID: 41**

0	0	8	3	7
---	---	---	---	---

System Name: Springfield Utility Board

Entry Point: EP-A (Willamette)

Sample Period: 12/2025

**Number of excursions this month:** \_\_\_\_\_ 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** \_\_\_\_\_ 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

FOR OHA USE ONLY \_\_\_\_\_

Minimum Water Quality Parameters as Set By

pH	<input type="text" value=""/>	
Alk	<input type="text" value=""/>	(Alkalinity)
PO4	<input type="text" value=""/>	(Orthophosphate)
Other	<input type="text" value=""/>	(_____)

**Print Name:** Dave Embleton

**Signature:**

**Date:** 1/2/2026

Send to DWP within 10 days after end of sampling period