

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9	-	-	-	Y
2	7.8	-	-	-	Y
3	7.9	-	-	-	Y
4	7.8	-	-	-	Y
5	7.9	-	-	-	Y
6	7.9	-	-	-	Y
7	7.9	-	-	-	Y
8	7.9	-	-	-	Y
9	7.9	-	-	-	Y
10	7.9	-	-	-	Y
11	7.9	-	-	-	Y
12	7.9	-	-	-	Y
13	7.8	-	-	-	Y
14	8.0	-	-	-	Y
15	8.0	-	-	-	Y
16	8.0	-	-	-	Y
17	8.0	-	-	-	Y
18	8.0	-	-	-	Y
19	8.0	-	-	-	Y
20	8.0	-	-	-	Y
21	8.0	-	-	-	Y
22	8.0	-	-	-	Y
23	7.9	-	-	-	Y
24	7.9	-	-	-	Y
25	8.0	-	-	-	Y
26	8.0	-	-	-	Y
27	8.0	-	-	-	Y
28	8.0	-	-	-	Y
29	8.0	-	-	-	Y
30	8.0	-	-	-	Y

(N = Excursion)

Total N's 0

ENTRY POINT _____

PWS ID: 41

0	0	8	3	7
---	---	---	---	---

System Name: Springfield Utility Board

Entry Point: EP-B (Thurston)

Sample Period: 11/2021

Number of excursions this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

FOR OHA USE ONLY _____

Minimum Water Quality Parameters as Set By

pH

Alk

(Alkalinity)

PO4

(Orthophosphate)

Other

(_____)

Print Name: Dave Embleton

Signature: 

Date: 12/6/2021

Send to DWP within 10 days after end of sampling period