



Water Quality Parameter Monitoring Form Lead and Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	off				Y
2	off				Y
3	off				Y
4	off				Y
5	off				Y
6	off				Y
7	off				Y
8	off				Y
9	off				Y
10	off				Y
11	off				Y
12	off				Y
13	off				Y
14	off				Y
15	off				Y
16	off				Y
17	off				Y
18	off				Y
19	off				Y
20	off				Y
21	off				Y
22	off				Y
23	7.6				Y
24					Y
25					Y
26	7.7				Y
27					Y
28					Y
29					Y
30					Y
31					Y
(No=N=Excursion) Total N's					0

<<Have Minimums been met for this day?

County: Lane Agency: REGION 2

ENTRY POINT

EP-C

PWS ID 4100837

SPRINGFIELD UTILITY BOARD

Sample Period: June / 2023

Month/Year

Number of excursion during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameters(s) fall below the minimum set by the State.

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH 7.0

Print Name: _____

Signature: _____

Date: _____

Send to DWS within 10 days after end of sampling period.