

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5	-	-	-	Y
2	7.5	-	-	-	Y
3	7.5	-	-	-	Y
4	7.6	-	-	-	Y
5	7.5	-	-	-	Y
6	7.5	-	-	-	Y
7	7.4	-	-	-	Y
8	7.5	-	-	-	Y
9	7.5	-	-	-	Y
10	7.6	-	-	-	Y
11	Off	-	-	-	N/A
12	Off	-	-	-	N/A
13	Off	-	-	-	N/A
14	Off	-	-	-	N/A
15	Off	-	-	-	N/A
16	Off	-	-	-	N/A
17	Off	-	-	-	N/A
18	Off	-	-	-	N/A
19	Off	-	-	-	N/A
20	Off	-	-	-	N/A
21	Off	-	-	-	N/A
22	Off	-	-	-	N/A
23	Off	-	-	-	N/A
24	Off	-	-	-	N/A
25	Off	-	-	-	N/A
26	Off	-	-	-	N/A
27	Off	-	-	-	N/A
28	Off	-	-	-	N/A
29	Off	-	-	-	N/A
30	Off	-	-	-	N/A
31	Off	-	-	-	N/A

(N = Excursion)

Total N's 0

ENTRY POINT

PWS ID: 41

0	0	8	3	7
---	---	---	---	---

System Name: Springfield Utility Board

Entry Point: EP-C (Weyco)

Sample Period: 10/2024

Number of excursions this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

FOR OHA USE ONLY

Minimum Water Quality Parameters as Set By

pH

Alk

(Alkalinity)

PO4

(Orthophosphate)

Other

()

Print Name: Dave Embleton

Signature: 

Date: 11/6/2024

Send to DWP within 10 days after end of sampling period