



## Water Quality Parameter Monitoring Form Lead and Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					Y
2	7.9				Y
3					Y
4					Y
5					Y
6					Y
7					Y
8					Y
9	7.7				Y
10					Y
11					Y
12					Y
13	7.6				Y
14					Y
15					Y
16	7.7				Y
17					Y
18					Y
19	7.6				Y
20					Y
21					Y
22					Y
23					Y
24	7.7				Y
25					Y
26					Y
27	7.7				Y
28					Y
29					Y
30					Y
31	7.6				Y

(No=N=Excursion) **Total N's** 0

<<Have Minimums been met for this day?	County: Lane      Agency: REGION 2  <h2 style="text-align: center;">ENTRY POINT</h2> <h1 style="text-align: center;">EP-D</h1> <p style="text-align: center;">PWS ID 4100837 SPRINGFIELD UTILITY BOARD</p> <p style="text-align: center;"><b>Sample Period:</b>    <u>Aug / 2021</u>    <i>Month/Year</i></p>
---	---

**Number of excursion during this month:**      0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameters(s) fall below the minimum set by the State.

### Reference

Minimum Water Quality Parameter(s) as set by State:  pH <span style="border: 1px solid black; padding: 5px; font-size: 1.2em;">7.0</span>
--

Print Name:      Dave Embleton

Signature:     

Date:      9-9-21

Send to DWS within 10 days after end of sampling period.