



## Water Quality Parameter Monitoring Form Lead and Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					Y
2					Y
3	7.6				Y
4					Y
5					Y
6					Y
7	7.6				Y
8					Y
9					Y
10	7.6				Y
11					Y
12					Y
13					Y
14	7.5				Y
15					Y
16	7.4				Y
17					Y
18					Y
19					Y
20	7.7				Y
21					Y
22					Y
23					Y
24	7.5				Y
25					Y
26					Y
27					Y
28	7.6				Y
29					Y
30					Y
31					Y
(No=N=Excursion) Total N's					0

<<Have Minimums been met for this day?
County: Lane      Agency: REGION 2

# ENTRY POINT

# EP-D

PWS ID 4100837

SPRINGFIELD UTILITY BOARD

**Sample Period:**    Sept / 2021  
*Month/Year*

**Number of excursion during this month:**      0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameters(s) fall below the minimum set by the State.

*Reference*

Minimum Water Quality  
Parameter(s) as set by State:

pH    7.0

Print Name:          Dan Embleton      
 Signature:          Dan Embleton      
 Date:          10-7-21      
 Send to DWS within 10 days after end of sampling period.