



## Water Quality Parameter Monitoring Form Lead and Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					Y
2					Y
3					Y
4					Y
5					Y
6					Y
7					Y
8	7.6				Y
9					Y
10					Y
11					Y
12					Y
13					Y
14	7.6				Y
15					Y
16					Y
17					Y
18					Y
19					Y
20					Y
21	7.5				Y
22					Y
23					Y
24					Y
25					Y
26					Y
27	7.7				Y
28					Y
29					Y
30					Y
31					Y
(No=N=Excursion) Total N's					0

<<Have Minimums been met for this day?
County: Lane      Agency: REGION 2

### ENTRY POINT

## EP-D

PWS ID 4100837  
SPRINGFIELD UTILITY BOARD

**Sample Period:**    June / 2023  
                                  *Month/Year*

**Number of excursion during this month:**                0          

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameters(s) fall below the minimum set by the State.

*Reference*

Minimum Water Quality  
Parameter(s) as set by State:

pH    7.0

Print Name: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Send to DWS within 10 days after end of sampling period.