Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrosion Control

ID#	Sample Location	pH	Y/N
1	1006 Old Orchard Ln	7.5	Y
2	1221 Kenray Loop	7.6	Y
3	1920 Olympic St.	7.5	Y
4	202 S. 18th St	7.8	Y
5	308 South 69th Pl.	8	Y
6	319 N. 33rd St.	7.8	Y
7	400 Moffitt Ln	7.9	Y
8	1225 S. 58th	7.9	Y
9	4155 Commercial Ave	7.6	Y
10	3975 E. 14th Av	7.9	Y
11	1006 Old Orchard Ln	7.5	Y
12	1221 Kenray Loop	7.7	Y
13	1920 Olympic St.	7.6	Y
14	202 S. 18th St	7.8	Y
15	308 South 69th Pl.	8	Y
16	319 N. 33rd St.	7.6	Y
17	400 Moffitt Ln	8	Y
18	1225 S. 58th	7.9	Y
19	4155 Commercial Ave	7.6	Y
20	3975 E. 14th Av	7.8	Y
			Y
			Y
			Y
			Y
			Y
			Y
			Y
			Y
			Y
			Y
			Y
			Y
			Y
			Y
			Y
(No=N=Excursion) **Total N's**			0

<<Has sample met the Minimums?

County: Lane Agency: REGION 2

DISTRIBUTION

PWS ID 4100837

SPRINGFIELD UTILITY BOARD

Sample Period: July/2024
Month/Year

LCR Sampling Period: June - Sept/2021

Sample Frequency: 2X during LCR sampling

Distribution Samples Required: 10

Number of excursion during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameters(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH **7.0**

Print Name: Dave Embleton

Signature:

Date: 9-19-24

Send to DWS within 10 days after end of sampling period.

OHA Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: https://www.oregon.gov/oha/ph/HealthyEnvironments/DrinkingWater