



Water Quality Parameter Monitoring Form Lead and Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					Y
2	7.5				Y
3					Y
4					Y
5	7.4				Y
6					Y
7					Y
8					Y
9	7.6				Y
10					Y
11					Y
12	7.5				Y
13					Y
14					Y
15					Y
16	7.6				Y
17					Y
18					Y
19					Y
20					Y
21					Y
22	7.6				Y
23					Y
24					Y
25					Y
26	7.6				Y
27					Y
28					Y
29	7.5				Y
30					Y
31					Y
(No=N=Excursion) Total N's					0

<<Have Minimums been met for this day?	County: Lane Agency: REGION 2 <h2 style="text-align: center;">ENTRY POINT</h2> <h1 style="text-align: center;">EP-E</h1> <p style="text-align: center;">PWS ID 4100837 SPRINGFIELD UTILITY BOARD</p> <p style="text-align: center;">Sample Period: <u>March/ 2021</u> <i>Month/Year</i></p>
---	--

Number of excursion during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameters(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State: <div style="display: flex; justify-content: center; align-items: center;"> pH <div style="border: 1px solid black; padding: 5px 15px; margin-left: 10px;">7.0</div> </div>

Print Name: Dave Embleton
 Signature: *Dave Embleton*
 Date: 4-6-21

Send to DWS within 10 days after end of sampling period.