



## Water Quality Parameter Monitoring Form Lead and Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2					Y
3					Y
4					Y
5					Y
6	7				Y
7	7.2				Y
8					Y
9	7.4				Y
10					Y
11					Y
12					Y
13	7.4				Y
14					Y
15	7.4				Y
16					Y
17					Y
18					Y
19	7.5				Y
20					Y
21					Y
22	7.5				Y
23	7.4				Y
24					Y
25					Y
26	7.4				Y
27					Y
28					Y
29					Y
30	7.5				Y
31					Y

(No=N=Excursion) **Total N's** 0

<<Have Minimums been met for this day?
County: Lane Agency: REGION 2

### ENTRY POINT

## EP-E

PWS ID 4100837  
SPRINGFIELD UTILITY BOARD

**Sample Period:** March/ 2021

*Month/Year*

**Number of excursion during this month:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameters(s) fall below the minimum set by the State.

*Reference*

Minimum Water Quality  
Parameter(s) as set by State:

pH 7.0

Print Name: David Embleton  
 Signature:   
 Date: 5-7-21

Send to DWS within 10 days after end of sampling period.