

Water Quality Parameter Monitoring Form Lead and Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N
1					
2	7.6				Y
3					Υ
4					Υ
5					Υ
6	7.7				Υ
7	7.6				Υ
8					Υ
9					Υ
10					Υ
11					Υ
12	7.6				Y
13					Υ
14	7.9				Υ
15					Υ
16					Υ
17					Υ
18					Υ
19	7.7				Υ
20					ΙvΙ
21	7.6				Υ
22					Υ
23	7.5				Υ
24					Υ
25					Y Y
26					Υ
27	7.7				Υ
28	7.8				Υ
29					Υ
30					Υ
31					Υ
(No=N=Excursion) Total N's					0

< <have< th=""><th></th><th>County: Lane</th><th>Agency: REGION</th><th>2</th></have<>		County: Lane	Agency: REGION	2	
Minimums been met for this day?	ENTRY POINT				
tins day.		EF	P-E		
PWS ID 4100837					
SPRINGFIELD UTILITY BOARD				ARD	
Sample Pe	riod:	July/ 2021 Month/Yea			
Number of excursion during this month: 0					

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameters(s) fall below the minimum set by the State.

Minimum Water Quality

Parameter(s) as set by State:				
	pH 7.0			
Print Name:	Dan Fre			
Signature:	Ture Er			
Date:	8-8-21			
Send to DWS within 10	days after end of sampling period.			

Reference