



## Water Quality Parameter Monitoring Form Lead and Copper Rule Corrosion Control

| Day                        | pH  | Alk | Phos | Other | Y/N |
|----------------------------|-----|-----|------|-------|-----|
| 1                          |     |     |      |       | Y   |
| 2                          |     |     |      |       | Y   |
| 3                          |     |     |      |       | Y   |
| 4                          |     |     |      |       | Y   |
| 5                          |     |     |      |       | Y   |
| 6                          |     |     |      |       | Y   |
| 7                          | 7.4 |     |      |       | Y   |
| 8                          |     |     |      |       | Y   |
| 9                          | 7.5 |     |      |       | Y   |
| 10                         |     |     |      |       | Y   |
| 11                         |     |     |      |       | Y   |
| 12                         |     |     |      |       | Y   |
| 13                         |     |     |      |       | Y   |
| 14                         |     |     |      |       | Y   |
| 15                         | 7.6 |     |      |       | Y   |
| 16                         |     |     |      |       | Y   |
| 17                         |     |     |      |       | Y   |
| 18                         | 7.7 |     |      |       | Y   |
| 19                         |     |     |      |       | Y   |
| 20                         |     |     |      |       | Y   |
| 21                         |     |     |      |       | Y   |
| 22                         | 7.6 |     |      |       | Y   |
| 23                         |     |     |      |       | Y   |
| 24                         |     |     |      |       | Y   |
| 25                         | 7.6 |     |      |       | Y   |
| 26                         |     |     |      |       | Y   |
| 27                         |     |     |      |       | Y   |
| 28                         | 7.5 |     |      |       | Y   |
| 29                         |     |     |      |       | Y   |
| 30                         |     |     |      |       | Y   |
| 31                         |     |     |      |       | Y   |
| (No=N=Excursion) Total N's |     |     |      |       | 0   |

<<Have Minimums been met for this day?
County: Lane Agency: REGION 2

### ENTRY POINT

## EP-E

PWS ID 4100837  
SPRINGFIELD UTILITY BOARD

**Sample Period:** February / 2022  
*Month/Year*

**Number of excursion during this month:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameters(s) fall below the minimum set by the State.

*Reference*

Minimum Water Quality  
Parameter(s) as set by State:

pH 7.0

Print Name: Dave Embleton  
 Signature:   
 Date: 3-8-22

Send to DWS within 10 days after end of sampling period.