



## Water Quality Parameter Monitoring Form Lead and Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					Y
2					Y
3	7.5				Y
4					Y
5					Y
6					Y
7					Y
8	7.7				Y
9					Y
10	7.5				Y
11					Y
12					Y
13	7.6				Y
14					Y
15	7.6				Y
16					Y
17					Y
18					Y
19					Y
20					Y
21	7.6				Y
22					Y
23					Y
24	7.7				Y
25					Y
26					Y
27					Y
28	7.3				Y
29	7.3				Y
30					Y
31					Y

(No=N=Excursion) **Total N's** 0

<<Have Minimums been met for this day?	County: Lane      Agency: REGION 2  <h2 style="text-align: center;">ENTRY POINT</h2> <h1 style="text-align: center;">EP-E</h1> <p style="text-align: center;">PWS ID 4100837 SPRINGFIELD UTILITY BOARD</p> <p style="text-align: center;"><b>Sample Period:</b>    <u>March / 2023</u>    <i>Month/Year</i></p>
--	---

**Number of excursion during this month:**      0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameters(s) fall below the minimum set by the State.

### Reference

Minimum Water Quality Parameter(s) as set by State:	
pH	7.0

Print Name: Dave Embleton  
 Signature:   
 Date: 4-6-23  
 Send to DWS within 10 days after end of sampling period.