



# Water Quality Parameter Monitoring Form Lead and Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1		---	---	---	Y
2		---	---	---	Y
3		---	---	---	Y
4	7.8	---	---	---	Y
5	7.7	---	---	---	Y
6		---	---	---	Y
7		---	---	---	Y
8		---	---	---	Y
9		---	---	---	Y
10		---	---	---	Y
11	7.8	---	---	---	Y
12		---	---	---	Y
13	7.8	---	---	---	Y
14		---	---	---	Y
15		---	---	---	Y
16		---	---	---	Y
17		---	---	---	Y
18	7.5	---	---	---	Y
19	7.8	---	---	---	Y
20		---	---	---	Y
21		---	---	---	Y
22		---	---	---	Y
23		---	---	---	Y
24		---	---	---	Y
25		---	---	---	Y
26		---	---	---	Y
27	7.6	---	---	---	Y
28		---	---	---	Y
29		---	---	---	Y
30		---	---	---	Y
31		---	---	---	Y
(No=N=Excursion) Total N's					0

<<Have  
Minimums  
been met for  
this day?

County: Lane

Agency: REGION 2

**ENTRY POINT**

**EP-E**

PWS ID 4100837

SPRINGFIELD UTILITY BOARD

**Sample Period:** March / 2025  
Month/Year

**Number of excursion during this month:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameters(s) fall below the minimum set by the State.

## Reference

Minimum Water Quality  
Parameter(s) as set by State:

pH **7.0**

Print Name:

Dave Embleton

Signature:

Date:

Send to DWS within 10 days after end of sampling period.

OHA Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <https://www.oregon.gov/oha/ph/HealthyEnvironments/DrinkingWater>