



## Water Quality Parameter Monitoring Form Lead and Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1		---	---	---	Y
2		---	---	---	Y
3		---	---	---	Y
4		---	---	---	Y
5		---	---	---	Y
6	7.9	---	---	---	Y
7	7.8	---	---	---	Y
8		---	---	---	Y
9		---	---	---	Y
10		---	---	---	Y
11		---	---	---	Y
12		---	---	---	Y
13	7.5	---	---	---	Y
14	7.7	---	---	---	Y
15		---	---	---	Y
16		---	---	---	Y
17		---	---	---	Y
18		---	---	---	Y
19		---	---	---	Y
20		---	---	---	Y
21	7.7	---	---	---	Y
22		---	---	---	Y
23		---	---	---	Y
24		---	---	---	Y
25		---	---	---	Y
26	7.5	---	---	---	Y
27	7.6	---	---	---	Y
28		---	---	---	Y
29		---	---	---	Y
30		---	---	---	Y
31		---	---	---	Y
(No=N=Excursion) Total N's					0

<<Have Minimums been met for this day?
County: Lane Agency: REGION 2

### ENTRY POINT

## EP-E

PWS ID 4100837  
SPRINGFIELD UTILITY BOARD

**Sample Period:** January / 2026  
Month/Year

**Number of excursion during this month:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameters(s) fall below the minimum set by the State.

*Reference*

Minimum Water Quality  
Parameter(s) as set by State:

pH 7.0

Print Name: Dave Embleton

Signature:

Date: 2-4-26

Send to DWS within 10 days after end of sampling period.