

Water Quality Parameter Form - **ENTRY POINT A (EP-A)**

**Lead & Copper Rule Corrosion Control**

**PWS Name/ID:** Stayton Water Supply - 4100843

**Sample Period (Month/Year):** AUGUST 2022

**Sample Frequency:** At least every 2 weeks

Day	pH	Alk	Phos	Other	yes/no
1					
2					
3	7.33	18			
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17	7.36	28			
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31	7.34	24			

< Have minimums been met for this day?

Total excursions during the previous five months: 0

(Over 9 excursions in 6 months is a violation. EP and Dist excursions are cumulative)

For OHA use only:	
Minimum Water Quality Parameters as set by OHA:	
<b>pH</b>	7.2
<b>Alkalinity</b>	16
PO4	
Other	

Total number of excursions for the month = **0**

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of the month

Print Name: Michael D. Bradley  
 Signature: Michael D. Bradley  
 Date: 8/31/2022