



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

06-04-2021

Table with columns: ID #, Sample Location, pH, Alk, PO4, other, Y/N. Contains handwritten data for three sample locations (Shop, Regis, Pine St.) across two sampling events.

06-25-2021

<Has sample met the minimums? DISTRIBUTION
PWS ID: 41 00843
System Name: City of Stayton
Sample Period: June 2021
Sample Frequency: 2 times a month
Distribution Samples required: 3

Number of excursions during this Sample Period = 0
(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.20
Alk 16 (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Michael D. Bradley
Signature: [Handwritten Signature]
Date: 06-30-2021

(N = No = Excursion) Total N's 0

Send to Drinking Water Program within 10 days after end of sampling period:
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/