

# OHA

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco

Agency: REGION 1

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1						
2						
3						
4	7.3		0.5		Y	
5						
6						
7						
8						
9						
10						
11	7.5		0.4		Y	
12						
13						
14						
15						
16						
17						
18	7.5		0.5		Y	
19						
20						
21						
22						
23						
24						
25	7.4		0.5		Y	
26						
27						
28						
29						
30						
31						
(No = N = Excursion)					Total N's	0

### WICKS ENTRY POINT

**EP-A****PWS ID 41-00869****THE DALLES, CITY OF**

Sample period: October 2023

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

#### Reference

#### Minimum Water Quality Parameter(s) as set by the State:

pH 7.0

PO4 0.4 (mg/L, Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date &amp; Phone: Nov 02, 2023; 541-298-2248 x 5000

Send to DWP within 10 days after  
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>