

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco Agency: REGION 1

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1						
2						
3						
4						
5						
6	7.2		0.5		Y	
7						
8						
9						
10						
11						
12						
13	7.4		0.5		Y	
14						
15						
16						
17						
18						
19						
20	7.2		0.5		Y	
21						
22						
23						
24						
25						
26						
27	7.4		0.5		Y	
28						
29						
30						
31						
(No = N = Excursion)					Total N's	0

WICKS ENTRY POINT

EP-A

PWS ID 41-00869

THE DALLES, CITY OF

Sample period: March 2024

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH

PO4 (mg/L, Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: 4/4/2024 541-298-2248 x 5010

Send to DWP within 10 days after the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>