

# OHA

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco Agency: REGION 1

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1						
2						
3						
4						
5						
6						
7						
8						
9	7.5		0.5		Y	
10						
11						
12						
13						
14	7.5		0.5		Y	
15						
16						
17						
18						
19						
20						
21	7.5		0.4		Y	
22						
23						
24						
25						
26						
27						
28	7.6		0.4		Y	
29						
30						
31						
(No = N = Excursion)					Total N's	0

### WICKS ENTRY POINT

EP-A

PWS ID 41-00869

THE DALLES, CITY OF

Sample period: August 2024

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

#### Reference

**Minimum Water Quality  
Parameter(s) as set by the State:**

pH

PO4  (mg/L, Orthophosphate)

Print Name: Dave Anderson

Signature: 

Date & Phone: 10-Sep-24 541-506-2008

Send to DWP within 10 days after  
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>