

**OHA**

**Water Quality Parameter Monitoring Form**  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	7.8		0.5		Y	
2						
3						
4						
5						
6						
7						
8	7.6		0.5		Y	
9						
10						
11						
12						
13						
14						
15						
16						
17						
18	7.5		0.5		Y	
19						
20						
21						
22						
23	7.5		0.5		Y	
24						
25						
26						
27						
28						
29	7.5		0.5		Y	
30						
31						

(No = N = Excursion)

Total N's 

County: Wasco Agency: REGION 1

**WICKS ENTRY POINT****EP-A****PWS ID 41-00869****THE DALLES, CITY OF**

Sample period: October 2025

Number of excursions during this month: 

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by the State:**

pH PO4  (mg/L, Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date &amp; Phone: 7-Nov-25 541-298-2248 x 5010

Send to DWP within 10 days after  
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>