

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco Agency: REGION 1

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1						
2						
3						
4						
5	7.3		0.6		Y	
6						
7						
8						
9						
10						
11	7.3		0.6		Y	
12						
13						
14						
15						
16						
17						
18	7.2		0.6		Y	
19						
20						
21						
22						
23						
24						
25	7.1		0.5		Y	
26						
27						
28						
29						
(No = N = Excursion)					Total N's	0

WICKS ENTRY POINT

EP-A

PWS ID 41-00869
THE DALLES, CITY OF

Sample period: February 2026

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.


Reference

Minimum Water Quality Parameter(s) as set by the State:

pH

PO4 (mg/L, Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date & Phone: 9-Mar-26 541-298-2248 x 5010

Send to DWP within 10 days after the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>